

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 5276-2122:0101

CATEGORY: 5276 -- CARBON MONOXIDE ALARMS

LISTEE: Defender Detectors Inc.P.O. Box 60177, Reno, NV 89506
Contact: Don Smith (800) 253-1529 Fax (775) 475-4402
Email: sales@defenderdetectors.com

DESIGN: Models CA6100 and CA6150 single station, sealed lithium battery operated carbon monoxide alarms with a 10 year End-of-Life signal that provides notice when devices need to be replaced. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Two 3 VDC FDK CR2/3 8-L lithium batteries.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes, NFPA 720, and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, and UL label.

APPROVAL: Listed as single station Carbon Monoxide alarms for residential applications. Refer to listee's Owner's Manual for installation details.

NOTE: Carbon Monoxide alarms are not intended/suitable for fire and smoke detection.

XLF: 5276-2056:0103

12-05-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division